



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER.....PUBLIC HEALTH ENGINEERING
SUB-DIVISIONPASIGHAT

No.AE/PHE/PSG/Lab-01/2025-2026

Dated Pasighat the 26th July' 2025

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Er. Takong Lego, Junior Engineer from PHE & W/S Sub-Division, Pasighat, inspected the Donyi Polo Vidya Niketan School, Pasighat on 25th July'2025 and on the basis of water test report (attached) bearing no. AE/PHE/PSG/Lab-01/2025-26/427, Dated Pasighat the 26th July'2025 of PHE & WS Division Laboratory certified that the Donyi Polo Vidya Niketan, Pasighat has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central State/U.T Govt.

This Certificate is valid upto 26/07/2026.


To,

The Principal

Donyi Polo Vidya Niketan School, Pasighat

East Siang District

Arunachal Pradesh


28/07/25
Assistant Engineer
Signature with seal
PHE & WS Sub-Division.....
Pasighat
Name: Er. Tajing Darang

Designation: Assistant Engineer

PHE & WS Sub-Division, Pasighat



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER.....PHE & WS DEPARTMENT
SUB-DIVISION : PASIGHAT
WATER QUALITY TEST REPORTS OF DONYI POLO VIDYA NIKETAN, PASIGHAT

No. AE/PHE/PSG/Lab-01/2025-26

1427

Dated Pasighat the 26th July'2025

Sl.No	Source Type	Date of Test	ALKALINITY	FLUORIDE	TOTAL HARDNESS	IRON	P ^H Value	CHLORIDE	NITRATE	SULPHATE	TDS	TURBIDITY	BACTERIOLOGICAL TEST
1	Bore Well	26-07-2025	40.0 mg/l	0.0 mg/l	00.1 mg/l	0.0mg/l	6.9	1.2 mg/l	0.424 mg/l	0.00 mg/l	42.9 ppm	0.43 NTU	0
	Acceptable Range		200 mg/l	1.5 mg/l	200 mg/l	0.3 mg/l	6.5 - 8.5	250 mg/l	45 mg/l	200 mg/l	500 mg/l	5 NTU	0

Result :- All the Parameters found are Normal

Lab-Technician
PHE & WS Sub-Division, Pasighat

Assistant Engineer
PHE & WS Sub-Division, Pasighat